

## **UTAH DIVISION OF AIR QUALITY** **MODIFIED SOURCE PLAN REVIEW**

George W. Cross, President  
Intermountain Power Service Corporation  
850 West Brush Wellman Road  
Delta, Utah 84624 RE:

Project fee code: N0327-010

|                             |  |
|-----------------------------|--|
| REVIEW ENGINEER:            | CO PSD Major Modification to DAQE-049-02 at Unit 1 and 2   |
| DATE:                       | Intermountain Generating Station                           |
| NOTICE OF INTENT SUBMITTED: | Millard County, Utah CDS-A, ATT, Title V, Title IV, NSPS   |
| PLANT CONTACT:              | Milka M. Radulovic   |
| PHONE NUMBERS:              | December 18, 2003  |
| FAX NUMBER:                 | November 4, 2002, March 24, 2003, & September 24, 2003     |
| SOURCE LOCATION:            | Rand Crafts  |
| UTM COORDINATES:            | (435) 864-6494   |
| REVIEW:                     | (435) 864-0994   |
|                             | 850 West Brush Wellman Road Delta, Millard County, Utah    |
|                             | 4,374.4 km Northing, 364.2 km Easting, Zone 12 datum NAD27 |

Peer Engineer \_\_\_\_\_

John Jenks

DAQ requests that a company/corporation official read the attached draft/proposed Plan Review with Recommended Approval Order Conditions. If this person does not understand or does not agree with the conditions, the PLAN REVIEW ENGINEER should be contacted within five days after receipt of the Plan Review. Special attention needs to be addressed to the Recommended AO Conditions because they will be recommended for the final AO. If this person understands and the company/corporation agrees with the Plan Review or Recommended AO Conditions, this person should sign below and return (can use FAX # 801-536-4099) within 10 days after receipt of the conditions. If the Plan Review Engineer is not contacted within 10 days, the Plan Review Engineer shall assume that the Company/Corporation official agrees with this Plan Review and will process the Plan Review towards final approval. A 30-day public comment period will be required before the Approval Order can be issued.

Thank You

Applicant Contact

\_\_\_\_\_  
(Signature & Date)

**OPTIONAL:** In order for this Source Plan Review and associated Approval Order conditions to be administratively included in your Operating Permit (Application), the Responsible Official as defined in R307-415-3, must sign the statement below and the signature above is not necessary. **THIS IS STRICTLY OPTIONAL!** If you do not desire this Plan Review to be administratively included in your Operating Permit (Application), only the Applicant Contact signature above is required. Failure to have the Responsible Official sign below will not delay the Approval Order, but will require a separate update to your Operating Permit Application or a request for modification of your Operating Permit, signed by the Responsible Official, in accordance with R307-415-5a through 5e or R307-415-7a through 7i.

**“Based on reasonable inquiry, I certify that the information provided for this**

**Approval Order has been true, accurate and complete and request that this  
Approval Order be administratively amended to the Operating Permit  
(Application)."**

Responsible Official \_\_\_\_\_

\_\_\_\_\_  
(Signature & Date)

N:\mradulov\word\review\IPP-December13.doc.doc

**TYPE OF IMPACT AREA**

|   |                       |
|---|-----------------------|
| Attainment Area   | Yes                   |
| NSPS  | Yes                   |
| 40 CFR Part 60, Subpart Da (Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After September 18, 1978), and Subpart Y (Coal Preparation Plants) |                       |
| NESHAP  | No                    |
| MACT  | No                    |
| Hazardous Air Pollutants (HAPs)   | Yes (from combustion) |
| Hazardous Air Pollutants Major Source<br>(No HAPs involved in modification)   | Yes                   |
| New Major Source  | No                    |
| Major Modification  | Yes                   |
| PSD Permit  | Yes                   |
| PSD Increment (modeling)  | Yes                   |
| Operating Permit Program  |                       |
| Area Source   | No                    |
| Major   | Yes                   |
| Send to EPA   | Yes                   |
| Comment period  | 30-day                |

**FOR MODIFIED SOURCES**

The Notice of Intent is for a modification to an existing source. The following standards are applicable to this review:

|  |     |
|--|-----|
| NSPS applies to modification?            | No  |
| CO PSD review of entire source required? | Yes |
| NESHAPS applies to modification?         | No  |
| HAPs involved in modification?           | No  |
| TITLE V required for entire source?      | Yes |
| HAPs MAJOR for modification?             | No  |
| NONATT MAJOR for entire source?          | No  |

### *Abstract*

*Intermountain Power Service Corporation (IPSC) operates the Intermountain Generating Station (IGS) coal fired steam-electric plant, consisting of two 950 MW units (approved in the DAQE-049-02), located near Delta in Millard County. IPSC is requesting a modification to their current approval order (AO) DAQE-049-02 to install combustion and NO<sub>x</sub> control system (overfire air) to accommodate the restriction on NO<sub>x</sub> emissions imposed by the Acid Rain Program regulations. In addition, IPSC is requesting the following:*

- Replacement-in-kind for the Boilers 1 & 2 low-NO<sub>x</sub> burners*
- To replace power supplies and motor drives to induced fans*
- To clarify and specify where surface-heating area was actually to be added in the Boilers 1 & 2 (approved in the AO DAQE-049-02)*
- Convert minor indoor fugitive emissions to point sources to vent outside*
- Upgrade plant Distributed Control System*
- Minor changes in the descriptions for clearness*

*Projected emission changes from this project are from zero to a potential 7,900 ton decrease from the current NO<sub>x</sub> PTE with concurrent increase of CO from zero to a potential 9,700 tons. Other pollutants emission rates, stack mass flow, stack temperatures, air contaminant types, and concentrations of air contaminants will remain the same. This project represents a major modification under the Prevention of Significant Deterioration (PSD) program since the proposed physical change can result in the significant emission increase for CO.*

*Air quality impact analysis of the CO maximum emission increases was performed and it showed that 1 and 8 hours impacts were well below significant impact levels. Furthermore, potential reduction in the target emissions of NO<sub>x</sub> is expected to improve visibility and expand available NO<sub>x</sub> increments.*

*Millard County is an attainment area of the National Ambient Air Quality Standards (NAAQS) for all pollutants. New Source Performance Standards (NSPS), Subpart Da and Subpart Y apply to this source. National Emission Standard for Hazardous Air Pollutants (NESHAP) do not apply to this source at this time. However, it is expected in near future NESHAP for new and existing coal and oil-fired electrical utility steam generating units. The proposed NESHAP would implement section 112(d) of the Clean Air Act by requiring certain coal- and oil-fired electric utility steam generating units to meet HAP emissions standards reflecting the application of the maximum achievable control technology (MACT). Boilers 1 & 2 are also Group 1, Phase II units under the Acid Rain Program. IPSC is a PSD major source of NO<sub>x</sub>, SO<sub>2</sub>, CO, and PM<sub>10</sub>. Title V of the 1990 Clean Air Act applies to this source. The Title V permit must be modified prior to operation of this modification.*

### **Newspaper Notice**

A notice of intent for the following project submitted in accordance with §R307-401-1, Utah Administrative Code (UAC), has been received for consideration by the Executive Secretary, Utah Air Quality Board:

Intermountain Power Service Corporation (IPSC), 850 West Brush Wellman Road, Delta, Utah.  
Project Location: 850 West Brush Wellman Road Delta, Millard County, Utah

Project Description: IPSC is requesting a modification to their current approval order (AO) DAQE-049-02 to install combustion and NO<sub>x</sub> control system (overfire air) to accommodate the restriction on NO<sub>x</sub> emissions imposed by the Acid Rain Program regulations. In addition, IPSC is proposing:

- Replacement-in-kind for the Boilers 1 & 2 low-NO<sub>x</sub> burners
- To replace power supplies and motor drives to induced fans
- To clarify and specify where surface-heating area was actually to be added in the Boilers 1 & 2
- Convert minor indoor fugitive emissions to point sources to vent outside
- To upgrade the plant distributed controls system
- Minor changes in the descriptions for clearness

The proposed emissions increases (in tons per year) will be as follows: CO 9702.7.

It has been determined that the conditions of the Utah Administrative Code R307-401-6 and the Federal rules have been met. The Executive Secretary intends to issue an Approval Order after a 30-day public comment period is held. This comment period is being held to receive and evaluate public input on the project proposed by Intermountain Power Service Corporation.

#### **I. DESCRIPTION OF PROPOSAL**

IGS is a fossil fuel-fired steam-electric generating station that primarily uses coal as fuel for the production of steam to generate electricity. Both bituminous and sub-bituminous coals are utilized. Fuel oil and used oil are also combusted for start-up, flame stabilization and energy recovery.

IGS is a two-unit facility currently approved to operate at a rated capacity of 950 megawatts (MW). Boiler capacity will be rated at 6.9 million pounds per hour of steam flow at 2,822 psi and 1005°F.

IGS has in place bulk handling equipment for the unloading, transfer, storage, preparation, and delivery of solid and liquid fuel to the boilers. No changes of this equipment are required nor expected. No changes in the usage of other raw materials or bulk chemicals are required nor expected.

#### **PROPOSED CHANGES:**

Rectified power drives and motors for induced fan motors need to be replaced due to obsolescence. IPSC has approval to increase surface area to the main boilers, and IPSC is now clarifying the location. IPSC is also requesting approval to install over-fire-airports in each boiler to enhance current operating strategies for controlling combustion and NO<sub>x</sub> emissions. IPSC had found that due to changing fuel quality, it appeared likely that additional combustion/NO<sub>x</sub> control such as OFA would be helpful in meeting Acid Rain program and permit conditions for continuous long term operation. **These changes are needed specifically for reliability, performance and/or routine maintenance needs, will not increase approved plant capacity.** IPSC is proposing to upgrade its distributed controls system. In addition, IPSC is

performing replacement in kind of Boiler #1 & #2 Low-NO<sub>x</sub> burners.

## **BACKGROUND**

On January 11, 2002, the Utah Division of Air Quality (UDAQ) issued to Intermountain Power Service Corporation (IPSC) an approval order (DAQE-049-02) to make certain modifications to the Intermountain Generating Station (IGS). On September 23, 2002, IPSC submitted a Notice of Intent (NOI) to clarify and adjust the scope of those modifications, known as the Dense Pack Uprate Project, as well as receive permitting for other changes. This review is being used to summarize the Dense Pack Project and certain other changes previously approved by UDAQ (DAQE-049-02).

Approval Order DAQE-049-02 allowed IPSC to make certain changes provided IGS operated those changes as a minor modification pursuant to actual to future actual provisions under Utah's Prevention of Significant Deterioration (PSD) rules. Changes allowed under that Approval Order as described in its original NOI included:

- Increasing heat input to main boilers
- Adding surface area to main boilers
- Replacing each unit high pressure turbine with new technology turbines
- Replacing one relief valve on each main boiler with one safety valve
- Adding wall rings to each scrubber module
- Adding helper cooling towers and cooling system enhancements
- Enhancements to generators, isophase & motor buses, transformers, boiler feed pumps, high pressure lines, control systems, and other similar changes.

### **The September 23, 2002 NOI and subsequent requests sought:**

- To clarify where surface area was actually to be added in main boilers
- To replace power supplies and motor drives to induced fans
- Replacement-in-kind for low-NO<sub>x</sub> burners
- To add over-fire air (OFA) ports to main boilers for combustion and NO<sub>x</sub> control.
- To provide outside venting for slurry tank that currently vent within scrubber buildings.
- To upgrade the plant distributed controls system.

Full descriptions of those changes were discussed in IPSC NOI and in subsequent letters, e-mails, and meetings between IPSC and DAQ staff. Additionally, in order to assess how OFA affects both NO<sub>x</sub> and CO emissions, an experimental AO was issued on February 14, 2003 to allow installation and testing of an OFA system on Unit 1 to establish relationship between CO and O<sub>2</sub> and NO<sub>x</sub> control effectiveness with over-fire air.

## **PERMIT OPTIONS**

Of particular interest for this NOI is how to treat the permitting for over-fire air (OFA). IPSC initially sought to have OFA permitting as a minor modification under certain PSD provisions. However, the testing of the OFA system is complete, the results showed that CO might increase

in major net significant amounts (greater than 100 tons per year) when NO<sub>x</sub> is controlled to low emission rates.

For the dense pack modifications, IPSC chose to modify combustion for NO<sub>x</sub> control during increased heat input, rather than utilize technological add-on controls. Combustion in the boiler was fine-tuned to optimize performance against NO<sub>x</sub> emissions using such methods as burner-out-of-service, excess oxygen control, fuel management, and other boiler operational changes.

Although such practices have been successful, IPSC believes that replacing this combustion methodology with OFA controls would better optimize boiler performance and control of NO<sub>x</sub> emissions.

The use of OFA will allow IPSC to control NO<sub>x</sub> without a significant net increase due to the dense pack modifications. However, IPSC believes it is possible that certain OFA configurations can cause a net significant increase in CO emissions. Therefore, IPSC seeks permitting of OFA as a major modification for CO under PSD.

#### **PRODUCTION SUMMARY:**

IPSC operates two power generating units, each 950 MWhe, with steam flow of 6.9 million pounds per hour, heat input of 9,225 million Btu per hour, requiring the use of 5.6 million tons of coal each year. See AO #DAQE-049-02 and its corresponding NOI for details. Nothing in the IPSC current NOI is intended to change those production aspects of the previously approved uprate project.

#### **EMISSION CHARACTERISTICS:**

During the boiler normal combustion with about 3% O<sub>2</sub> in the flue gases with currently typical coal, IPP is able to operate under their NO<sub>x</sub> emissions limit of 0.461 lb/MMBtu and CO level of 1989.6 tons per year. As coal reserve change, it is anticipated that operating in the same fashion would cause NO<sub>x</sub> emissions potential value to raise and potentially exceed NO<sub>x</sub> emissions limit. The solution is introducing the OFA system, which actually reduces excess O<sub>2</sub> and NO<sub>x</sub> emissions and thus allows use of variety of coals without exceeding the NO<sub>x</sub> emissions limit. Along with this NO<sub>x</sub> control, it will be a potential commensurate increase in CO emissions up to 180 ppm (0.143 lb/MMBtu boiler heat input) and potential to emit (PTE) CO emissions of 11,692.3 tons per year.

The composition and physical characteristics of emissions resulting from the proposed modifications will not change with the exception of carbon monoxide (CO), which may increase by a net significant amount. Other pollutant emission rates, chimney mass flow, temperature, air contaminant types, and concentration of air contaminants will remain the same as proposed in the uprate project. The current pollution control devices (PCD) include low-NO<sub>x</sub> burners, fabric filters and wet scrubbers. No increases in PTE for any pollutant except for CO will occur as a result of this modification.

Specifically, it is possible for CO emissions to increase as over-fire air (OFA) is used to decrease

NO<sub>x</sub> emissions. When NO<sub>x</sub> emissions are fully minimized utilizing OFA, IPP expected that CO emissions could increase from 1989.6 tons per year (as calculated by AP-42- EPA's compilations of emission factors, and verified with testing) to 11,692.3 tons per year (as projected by boiler testing).

The following 30-day block average emission rate parameters are provided as required:

| Parameter         | Current Before PCD | Expected After PCD | Potential change after modification |
|-------------------|--------------------|--------------------|-------------------------------------|
| Particulates      | 96,000 lbs/hr      | 50 lbs/hr          | none                                |
| Nitrogen Oxides   | 0.42 lbs/MMBtu*    | 0.40 lbs/MMBtu     | 0.37 lbs/MMBtu minimum              |
| Sulfur Dioxide    | 1.8 lbs/MMBtu      | 0.06 lbs/MMBtu     | none                                |
| Carbon Monoxide   | 0.022 lbs/MMBtu**  | 0.040 lbs/MMBtu    | ***0.143 lbs/MMBtu maximum          |
| Temperature       | 325 F              | 120 F              | none                                |
| Stack Gas Volume  | 130,000,000 scfh   | 130,000,000 scfh   | none                                |
| VOC               | 1.71 lb/hr         | 1.71 lb/hr         | immeasurable                        |
| Hydrochloric Acid | 0.67 lbs/hr        | 0.02 lbs/hr        | none                                |
| Hydrofluoric Acid | 0.14 lbs/hr        | 0.004 lbs/hr       | none                                |
| Antimony          | 0.007 lbs/hr       | 0.000008 lbs/hr    | none                                |
| Arsenic           | 0.03 lbs/hr        | 0.00006 lbs/hr     | none                                |
| Beryllium         | 0.0009 lbs/hr      | 0.0000005 lbs/hr   | none                                |
| Cadmium           | 0.001 lbs/hr       | 0.00001 lbs/hr     | none                                |
| Chromium          | 0.06 lbs/hr        | 0.0001 lbs/hr      | none                                |
| Cobalt            | 0.006 lbs/hr       | 0.00001 lbs/hr     | none                                |
| Lead              | 0.013 lbs/hr       | 0.00003 lbs/hr     | none                                |
| Manganese         | 0.016 lbs/hr       | 0.00005 lbs/hr     | none                                |
| Mercury           | 0.0001 lbs/hr      | 0.00001 lbs/hr     | none                                |
| Nickel            | 0.009 lbs/hr       | 0.00005 lbs/hr     | none                                |
| Selenium          | 0.005 lbs/hr       | 0.00065 lbs/hr     | none                                |

**NOTES:**

\*NO<sub>x</sub> emissions are estimated after low NO<sub>x</sub> combustion.

\*\*Current CO emissions based upon AP-42 factors and testing with OFA;

\*\*\*modified CO emissions based upon testing.

Carbon monoxide (CO) emission rates are provided based upon two different derivations. The current CO rate of 0.022 lbs/MMBtu is based upon AP-42 calculations (this value was also shown to be the same in the testing performed before the OFA). The projected CO rate is based upon testing of over-fire air. The increase from a current calculated rate to a projected rate is about 9,700 tons for the plant NO<sub>x</sub> emissions can concurrently decrease up to 7,900 tons from plant PTE.

**Pollution Control Device Description:**



Present pollution control device equipment for combustion for the Unit 1 and 2 boilers includes dual-register low NO<sub>x</sub> burners, baghouse type fabric filters for particulate removal, and flue gas desulfurization scrubbers. Control equipment for the handling and transfer of solid material include dust collection filters.

#### **Pollution Control Device Upgrade:**

The project includes the addition of overfire air (OFA) ports and replacement or repair of dual register low NO<sub>x</sub> burners.

#### **Description of the Over-fire Air (OFA) System and Control Devices.**

The most effective means of reducing fuel-based NO<sub>x</sub> formation is to reduce oxygen (air) availability during the critical step of devolatilization. Additional air can be added later in the process to complete char reactions and maintain high combustion efficiency. Oxygen availability can be reduced during devolatilization in two ways. One method is to remove a portion of the combustion air from the burners and introduce it elsewhere. This is how an OFA system works. It takes air from the burners and reintroduces it later in the combustion process above the burner rows. The second method is by burner design. The burner can be designed to supply all of the combustion air but to limit its rate of introduction to the flame. Only a fraction of the air is permitted to mix with the coal during devolatilization. The remaining air is then mixed downstream in the flame to complete combustion. With a low NO<sub>x</sub> burner, overall mixing is reduced and the flame envelope is large compared to rapid mixing conventional burners.

Overfire air is needed, in part, to accommodate the restriction on NO<sub>x</sub> emissions imposed by Acid Rain program regulations that were promulgated based upon the Clean Air Act Amendments of 1990. Specifically, in 2007, Acid Rain requirements impose a 0.46 lb/MMBtu annual cap for NO<sub>x</sub> emissions on IPP. Since an early election was filed for IPP, this new limit was delayed. Current forecasts of coal quality indicate that without OFA, the new Acid Rain program limit could be difficult to attain. A multiport over-fire air system will be added to ensure stable operation in accordance with specified emissions limits. The OFA system will redirect approximately 10-15 percent of total combustion air to a staged system of ports located directly above the top row of burners.

The OFA system at the Intermountain Generating Station (IGS) is being provided by Babcock Power, Inc. (BPI). It consists of one row of OFA ports located on the elevation immediately above the top burner levels on both the front (south) and rear (north) sides of the boiler. Each row consists of eight, identical, OFA ports with one port located over each of the six burner columns (column ports) and one port located on each end of the OFA rows near the side walls of the boiler (wing ports).

Air to the OFA system is provided by the Secondary Air (SA) system. A feeder duct extends from each SA header duct to the corresponding OFA header through which secondary air is admitted to the OFA headers. Each OFA feeder duct includes isolation dampers operated by Jordan rotary electrical drives.

OFA airflow to the boiler is admitted and controlled through the OFA port dampers. Each OFA port is partitioned into separate 1/3 and 2/3 sections. Airflow, through each set of OFA ports, is controlled by port dampers located in each partition. The four, 1/3 port dampers for an OFA row half are connected or ganged together for simultaneous operation by a Jordan rotary electrical drive. The same configuration is implemented for the 2/3 port damper sets. This creates a total of four, 1/3 port dampers/drives and four, 2/3 port dampers/drives for over-air flow control to the boiler.

Control and monitoring of all OFA damper drives is done by the IGS combustion control system. Additionally, an array of three Air Monitor Corporation VOLU-probes and thermocouples measures OFA mass flow through each of the four feeder ducts. Control signals operate all port dampers simultaneously; independent damper control is not available.

#### **Control Strategy Description**

More detailed information is in the documentation provided by Babcock Power Interface included in the "Report on Good Combustion Practices".

OFA is most effective controlling NO<sub>x</sub> formation at unit loads above 60% of the rated load of 950 MW. When utilized at the 60% load point and above, OFA flow will be accomplished by the combination of opening OFA feeder and port dampers and decreasing the combustion air damper positions, so as to maintain target total SA flow based on unit load.

The OFA port and feeder duct damper groups have modulating capability and can be operated either fully open, fully closed, or throttled to positions in-between. (Open position can be biased to achieve balanced O<sub>2</sub> distribution across the burner front). SA airflow to the OFA system is attained by simultaneously decreasing the openings of all the combustion air dampers feeding each of the burner elevations that are in operation. This decrease is superimposed on the existing automatic control biasing of each elevation combustion air in accordance with pulverizer loading.

This SA damper control is additive to the existing bias required to change burner airflow in proportion to the individual pulverizer load. The action of the sum of both biases will result in less secondary air directly to the burners, as OFA is being introduced, but the relative secondary air distribution between burner elevations will remain unchanged.

The OFA port relative open area sizes, 1/3 and 2/3, are calculated to provide the correct velocity of the OFA to attain the proper penetration of the OFA into the combustion region of the furnace above the burners. All ports of a given kind, 1/3 or 2/3, will open or close following a program designed to open the correct area to roughly produce the proper penetration velocity as the OFA air flow rate changes with boiler load. OFA operation will include the following configurations:

- All 1/3 and 2/3 ports closed
- 1/3 ports open, 2/3 ports closed
- 1/3 ports closed, 2/3 ports throttled

1/3 ports closed, 2/3 ports open


**Target Operating Parameters for OFA Design**

The OFA modifications shall provide for a continuous boiler rating of 6,900,000-lbs/hr output at 1005°F superheat and 1005°F reheat temperature under normal operating conditions. These modifications shall include the design, fabrication and installation on both IGS Units 1 & 2 for an overfire air system capable of providing a reduction in NO<sub>x</sub> emissions of 15% and consistent NO<sub>x</sub> emissions of less than 0.40 lbs/MMBtu under all operating modes.

Of particular interest to IPSC were the performance parameters associated with operation at 950 Megawatts gross generation (6.75 MMBtu/hr steam flow). These include:

- a. Total NO<sub>x</sub> output of 0.40 lbs/MMBtu or less up to an overall reduction of 15%. Current maximum average of 0.461 lbs/MMBtu.
- b. Superheat and reheat temperatures as well as NO<sub>x</sub> emissions must remain within acceptable ranges.
- b. Minimal impact on average unburned carbon (LOIs) and carbon monoxide (CO) concentrations within the boiler.

## O2% (control room) vs CO ppm (stack test) & NOx #/mbtu (stack CEM) Overfire Air (14%) OFA 2/3 dampers- full open



December 15, 2003  
Page 12